ADDENDUM

Addendum No. 2

Owner:	City of Owosso
Project:	Cargill Access Road
Engineer:	OHM/City of Owosso

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: August 3, 2016

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the *Signature Page and Legal Status* section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

<u>ITEM NO. 1:</u>

Section Entire Section [Title] Bid Proposal Pages 1 through 6

Remove *Bid Proposal pages 1 through 6* (begins at page 3 of the bid document) and insert revised *Bid Proposal pages 1 through 6.* The revised section is included as an attachment to this Addendum.

Reason is that a price for possible removal of (500) cubic yards of material is being included in the bid.

<u>ITEM NO. 2</u>

Water Main Materials Clarification: Fittings that meet either AWWA C110 or AWWA C153 are both acceptable; however, those meeting AWWA C153 are preferred.

ITEM NO. 3

Miscellaneous questions and answers listed below:

- 1) Is there any AIS or domestic only specification for this project? Yes. Page 1 of the water main spec states "Michigan and United States of America products shall be used whenever possible"
- 2) Are Mueller or American Flow Control Gate Valves permissible to quote? No. EJIW City standard
- 3) Are NEENAH (MDOT) castings permissible to quote? No. EJIW City standard

4) Are compact C153 ductile iron fittings permissible? Spec reads C110 full body fittings.

Yes. C153 fittings preferred. This has been acknowledged in the addendum to be released.

I acknowledge receipt of Addendum No. 2.

(PLEASE TYPE OR PRINT BELOW)

LEGAL	NAME OF BIDDER:				
MAILIN	IG ADDRESS:				
CITY, S	STATE, ZIP:				
TELEPHONE NUMBEREM		EMAIL I.D		_ FAX #	
BY:	SIGNATURE:				
	OF AUTHORIZED REPRE	ESENTATIVE			
	NAME (typed/printed)		TITLE:		

END OF ADDENDUM NO. 2