

ADDENDUM No. 4

City of Owosso Michigan

Name of Contract:

WTP SCADA UPGRADES

MODIFICATIONS TO CONTRACT DOCUMENTS:

SPECIFICATION MODIFICATIONS:

1. None.

DRAWING MODIFICATIONS:

Sheet E-003:

1. Delete control panel CP-FCP.
2. For CP-HSCP panel - Change 1-inch conduit shown with 3#10 to LP-8 to 1-inch conduit with 6#10 to LP-8.

Sheet E-300:

1. For CP-HSCP - Change homerun shown to LP-1 to be LP-8.
2. Clarification – CP-HSCP is located in the filter room on a new concrete pad.

Sheet E-301:

1. For the 2" conduit with 20 – 50u multimode zip cords, change the destination from MPP to NP-1.

Sheet E-303:

1. Change 1-inch conduit shown with 3#10 to LP-8 to 1-inch conduit with 6#10 wires from NP-1 to LP-8.

Sheet I-100:

1. Clarification - The Genetec camera software to be provided shall be the latest version.
2. Within the "Camera Server and Viewing Computer System Partial Bill of Material" change GENETEC VERSION UPGRADE to GENETEC VERSION and delete the word "5.6 TO". Note this is a new installation and the Owner does not currently own GENETEC software.