

ADDENDUM

Addendum No. 1

Owner: City of Owosso
Project: 2020 Street Program – Contract 2
Engineer: City of Owosso / OHM Advisors

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: January 21, 2020

=====

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the “*Signature Page and Legal Status*” section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Remove Bid Item No. 120 (Curb Box, Stop, ¾ inch Corporation Stop Connection, Modified) and insert Bid Item No. 120: “Curb Box, Stop, 1 inch Corporation Stop and Connection, Modified” with a quantity of 39 each.

Remove page 9 and insert the attached revised bid quantities sheet due to the above change.

END OF ITEM NO. 1

ITEM NO. 2:

Add “2020 Street Program - Contract 2 Questions” to the Contract Documents.

Add EPA form 6100-2 to the Contract Documents to be submitted with the bid proposal.

END OF ITEM NO. 2

END OF ADDENDUM NO. 1

Item	Description	Approx. Quantity	Unit	Unit Price	Total Price
107	Water Main, C909 PVC, 6 inch, TB Detail G, Modified	5	Ft		
108	Water Main, C909 PVC, 8 inch, TB Detail G, Modified	363	Ft		
109	Water Main, C900 PVC, 8 inch, Bore	601	Ft		
110	Water Main, C909 PVC, 12 inch, TB Detail G, Modified	438	Ft		
111	Water Main, C909 PVC, 12 inch, Bore	995	Ft		
112	Water Main, 4 inch, Cut and Plug, Modified	1	Ea		
113	Water Main, 6 inch, Cut and Plug, Modified	2	Ea		
114	Water Main, 12 inch, Cut and Plug, Modified	4	Ea		
115	Gate Valve and Box, 6 inch, Modified	2	Ea		
116	Gate Valve and Box, 8 inch, Modified	3	Ea		
117	Gate Valve and Box, 12 inch, Modified	5	Ea		
118	Fire Hydrant and Valve Assembly	10	Ea		
119	1" Copper Service Lead, Type "K", Modified	935	Ft		
120	Curb Box, Stop, 1 inch Corporation Stop and Connection, Modified	39	Ea		

2020 Street Program - Contract 2 Questions

- Q: Is there a pre-bid meeting scheduled for this project? In the DBE Portion of the proposal it references a pre-bid meeting but I haven't been able to find anything scheduled in the proposal.
- A: No, there is not a pre-bid meeting for this project. The DBE language from the Michigan Department of EGLE requires EPA form 6100-2 to be filled out by the contractor. This form is attached and shall be turned in with the bid proposal.
- Q: Water service pay item is calling out 3/4" corporation stop with 1" curb stop and 1" copper water line. Is this correct?
- A: The 3/4" corporation stop should be a 1" corporation stop. Bid Item No. 120 has been modified to reflect this change.
- Q: Supply & Install Meter Pit, Complete: The special provision states "The City of Owosso will provide the materials for the install of the meter pit."
- Are contractors to supply (provide) meter pit materials?
- A: City of Owosso DPW will supply all meter pit materials.
- Q: Will the water services need to be bored? We are reconstructing the total road width. It would seem we would be able to open cut these.
- A: The long side services shall be bored. The short side services shall be open cut.
- Q: After looking over everything we wondered if pricing every item covers the "All or None" clause or if there was a specific place where we had to state it was all or nothing.
- A: Pricing every item is sufficient for the "All or None" clause.
- Q: The industry standard for 3E3 is a PG 58-22 or PG 58-28 liquid for the base course. Would you be able to clarify/confirm please? 3E3 is shown as PG 64-28 on the current plans.
- A: The Performance Grade for asphalt binder for the 3E3 mix shall be PG 64-28.
- Q: Do you have an Excel Sheet with the bid items and quantities that you can provide?
- A: Yes. It will be included as a file as a part of this addendum. **The Excel Sheet should be used as a tool only. Bidders shall still fill out and initial the bid sheets in the bid proposal and submit with their bid.**

Disadvantaged Business Enterprise (DBE) Program DBE Subcontractor Participation Form

An EPA Financial Assistance Agreement Recipient must require its prime contractors to provide this form to its DBE subcontractors. This form gives a DBE¹ subcontractor² the opportunity to describe work received and/or report any concerns regarding the EPA-funded project (e.g., in areas such as termination by prime contractor, late payments, etc.). The DBE subcontractor can, as an option, complete and submit this form to the EPA DBE Coordinator at any time during the project period of performance.

Subcontractor Name		Project Name	
Bid/ Proposal No.	Assistance Agreement ID No. (if known)	Point of Contact	
Address			
Telephone No.		Email Address	
Prime Contractor Name		Issuing/Funding Entity:	

Contract Item Number	Description of Work Received from the Prime Contractor Involving Construction, Services, Equipment or Supplies	Amount Received by Prime Contractor

¹ A DBE is a Disadvantaged, Minority, or Woman Business Enterprise that has been certified by an entity from which EPA accepts certifications as described in 40 CFR 33.204-33.205 or certified by EPA. EPA accepts certifications from entities that meet or exceed EPA certification standards as described in 40 CFR 33.202.

² Subcontractor is defined as a company, firm, joint venture, or individual who enters into an agreement with a contractor to provide services pursuant to an EPA award of financial assistance.



OMB Control No: 2090-0030
Approved: 8/13/2013
Approval Expires: 8/31/2015

Disadvantaged Business Enterprise (DBE) Program DBE Subcontractor Participation Form

Please use the space below to report any concerns regarding the above EPA-funded project:

Subcontractor Signature	Print Name
Title	Date

The public reporting and recordkeeping burden for this collection of information is estimated to average three (3) hours per response. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates, and any suggested methods for minimizing respondent burden, including through the use of automated collection techniques to the Director, Collection Strategies Division, U.S. Environmental Protection Agency (2822T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.