

ADDENDUM

Addendum No. 1

Owner: City of Owosso
Project: 2024 Storm Sewer Televising Project
Engineer: City of Owosso

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: November 21, 2023 at 3pm

=====

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the "*Signature Page and Legal Status*" section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Add "2024 Storm Sewer Televising Project Questions" to the Contract Documents.

END OF ITEM NO. 1

END OF ADDENDUM NO. 1

2024 Storm Sewer Televising Project Questions

Q: Will there be any cost for water (hydrant) for the Cleaner Truck?

A: The contractor shall supply their own water for the work. Hydrant meters are available at Owosso DPW. \$1,000 prepayment is required. This covers usage of the water meter/RPZ and bulk water prepayment per the following charges: bulk water rate is \$12 per 1,000 gallons with a \$60 minimum charge which includes the first 5,000 gallons. When water meter and RPZ are returned in good condition, \$450 will be returned less any water use over the minimum charge for 5,000 gallons.

Q: Is there a disposal facility for the debris collected?

A: The contractor shall be responsible for disposal of debris. The city does not have an available dump site.

Q: Is the scope of the project to clean all debris from pipe or to be able to get the camera through and still have a quality video?

A: Pipe shall be cleaned to ensure a complete clear video inspection meeting PACP standards.

Q: Are easement machines allowed for areas not assessable for the Cleaner?

A: Yes, easement machines are allowed.

Q: Have all the manholes been located and exposed?

A: A few manholes are believed to be buried as noted on the maps.

Q: Due to potential interruptions and difficulty getting trucks to manholes along with bad road conditions because of winter weather can the project start date be sooner?

A: The project can begin after contracts are signed and a notice to proceed is issued. It usually takes about 30 days after bids are received for contracts to be signed.

Q: Can the city assist with locating and exposing any of the buried manholes?

A: For Clyde Street: We are hoping that the camera can enter STM-2105, travel east, and find STM-2092. Once the measurement is obtained, Owosso DPW will excavate the street and raise the manhole lid to grade.

For all other streets: The city of Owosso vac truck operator can assist with finding manholes.

Q: Is a bid bond required for this project?

A: No, a bid bond is not required.