

ADDENDUM

Addendum No. 1

Owner: City of Owosso
Project: 2023 Storm Sewer Lining Project
Engineer: City of Owosso

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: December 20, 2022

=====

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the "*Signature Page and Legal Status*" section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Add "2023 Storm Sewer Lining Project Questions" to the Contract Documents.

END OF ITEM NO. 1

END OF ADDENDUM NO. 1

2023 Storm Sewer Lining Project Questions

Q: Would the city accept air inversion and steam cure while collecting the condensate and any resins in the drainage structures?

A: The city will accept air inversion and steam cure for this project.

Q: In lieu of collecting the water from the curing process, would the city approve of the use of non-styrenated resin for the project?

A: The resin must be styrene-based in accordance with ASTM F1216