

ADDENDUM

Addendum No. 1

Owner: City of Owosso
Project: 2023 Sewer Televising Project
Engineer: City of Owosso

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: April 18, 2023

=====

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the "*Signature Page and Legal Status*" section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Add "2023 Sewer Televising Project Questions" to the Contract Documents.

END OF ITEM NO. 1

END OF ADDENDUM NO. 1

2023 Sewer Televising Project Questions

Q: Is the city responsible for the disposal of the catch basin debris removed?

A: The contractor will be responsible for cleaning any necessary debris from catch basins and disposal of debris.

Q: Is the CCTV price to include light cleaning (3 passes)? If water levels are high a vactor would be necessary to pull that water back in order to camera.

A: CCTV price includes cleaning sewers for televising operations. If more than 3 passes are necessary, the heavy cleaning pay item will be used.

Q: Is a bid bond required for this project?

A: No, a bid bond is not required for this project.