

ADDENDUM

Addendum No. 1

Owner: City of Owosso
Project: GE Powerbreak II 2500A Breaker Bid

NOTICE TO ALL PROSPECTIVE BIDDERS

BIDS DUE: October 25, 2022

=====

This Addendum is a part of the Contract Documents and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the "*Signature Page and Legal Status*" section of the Bid Proposal. Failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Add start up and testing requirements for the breaker and trip unit. Add a one-year warranty on labor and equipment.

Remove page 5 "General Specifications" and insert the attached revised "General Specifications" page.

END OF ITEM NO. 1

END OF ADDENDUM NO. 1

GENERAL SPECIFICATIONS

In-kind replacement of **GE Powerbreak II 2500A breaker with Entelliguard trip** unit at the City of Owosso Wastewater Treatment Plant. Photos of the existing breaker/trip unit are attached, and new breaker and trip unit specifications shall be identical, including 1600A plug. New breaker model must be GE Powerbreak II and trip unit must be Entelliguard. **No equivalent make/models will be accepted.**

Bid to include all necessary parts and labor to install the breaker and trip unit, to program the trip unit for proper operation and to startup and test for proper operation. Bid also to include current lead time for all parts.

Bid to include one year warranty on labor and equipment.

Installation work to be coordinated around wastewater plant operations, which may necessitate work outside normal business hours.

Bidders that have no work history with the Owosso Wastewater Treatment Plant since 2015 must meet on site with the Plant Superintendent or his representative prior to submitting a bid. Meetings shall be scheduled at least 24 hours in advance by contacting Tim Guysky, WWTP Superintendent at (517) 214-4202.